






Test Report issued under the responsibility of:



TEST REPORT IEC 61008-1 Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) Part 1: General rules	
Report Number.....:	2247906.50
Date of issue	2020-07-09
Total number of pages.....:	144
Name of Testing Laboratory preparing the Report.....:	DEKRA Certification B.V.
Applicant's name	ETI Elektroelement d.o.o.
Address	Obrezija 5, SI-1411 Izlake, Slovenia
Test specification:	
Standard.....:	IEC 61008-1:2010 (Third Edition) +A1:2012 +A2:2013 used in conjunction with IEC 61008-2-1:1990 (First Edition) or IEC 61008-2-2:1990 (First Edition)
Test procedure.....:	CB Scheme
Non-standard test method.....:	N/A
Test Report Form No.:	IEC61008_1H
Test Report Form(s) Originator	OVE
Master TRF	Dated 2015-11
Copyright © 2015 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	


Test item description	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)	
Trade Mark	ETI	
Manufacturer	ETI Elektroelement d.o.o., Obrezija 5, SI-1411 Izlake, Slovenia	
Model/Type reference	EFI-P2, EFI-P2R	
Ratings	16 A, 25 A, 32 A, 40 A, 63 A, 80 A / 30 mA, 100 mA, 300 mA, 500 mA / Type A, AC / 230 V, 240 V / 2p (1p+N) / 50/60 Hz	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/> CB Testing Laboratory:	DEKRA Certification B.V.	
Testing location/ address	Meander 1051, 6825 MJ Arnhem, The Netherlands	
<input type="checkbox"/> Associated CB Testing Laboratory:		
Testing location/ address		
Tested by (name, function, signature)		
Approved by (name, function, signature) ..		
Testing procedure: CTF Stage 1:		
Testing location/ address		
Tested by (name, function, signature)		
Approved by (name, function, signature) ..		
Testing procedure: CTF Stage 2:		
Testing location/ address	ETI Elektroelement d.o.o., Obrezija 5, SI-1411 Izlake, Slovenia	
Tested by (name + signature).....	Branko Pesan Urban Majdič Andjelko Petrušič	
Witnessed by (name, function, signature) .:	R. Verhagen	
Approved by (name, function, signature) ..	F.S. Strikwerda	
Testing procedure: CTF Stage 3:		
Testing procedure: CTF Stage 4:		
Testing location/ address		
Tested by (name, function, signature)		
Witnessed by (name, function, signature) .:		


Approved by (name, function, signature) .. :		
Supervised by (name, function, signature) :		

List of Attachments (including a total number of pages in each attachment): European group differences and national differences test report: 35 pages EMC test report (issued by SIQ Slovenia): 47 pages	
Summary of testing:	
Tests performed (name of test and test clause): Type test according to IEC 61008-1:2010+A1:2012+A2:2013 (Simplified test procedure). For details see page 10, 11.	Testing location: Test laboratory 1: DEKRA Certification B.V. Meander 1051 6825 MJ, Arnhem The Netherlands Test laboratory 2: ETI Elektroelement d.o.o. Obrezija 5 SI-1411 Izlake Slovenia Test laboratory 3: ICEM-TC Celovška cesta 1 SI-2351 Kamnica Slovenia Test laboratory 4: SIQ Ljubljana Varnost in elektromagnetika Mašera-Spasičeva ulica 10 SI-1000 Ljubljana Slovenia
Summary of compliance with National Differences (List of countries addressed): <input checked="" type="checkbox"/> The product fulfils the requirements of IEC 61008-1:2010 + A1:2012 + A2:2013, EN 61008-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2017 used in conjunction with EN 61008-2-1:1994 + A11:1998 and AS/NZS 61008.1:2015	

Copy of marking plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.





Test item particulars	
Classification of RCCBs functionally dependent on the / line voltage	
Opening automatically in case of failure of the line / voltage.....	
- reclosing automatically when the line voltage is restored	No
- not reclosing automatically when the line voltage is restored	Yes
Not opening automatically in case of failure of the line voltage.....	
- able to trip in a hazardous situation arising on failure of line voltage.....	No
- not able to trip in a hazardous situation arising on failure of line voltage	Yes
Type of RCCB	
- type AC	Yes
- type A.....	Yes
- independent of the line voltage	Yes
- dependent on the line voltage.....	No
- without time delay	Yes
- with time delay: type S	No
- enclosed.....	No
- unenclosed.....	Yes
- IP number.....	IP 20
- for fixed installation	Yes
- for mobile installation.....	No
Number of poles.....	2
Ambient air temperature (°C).....	
Method of mounting	On DIN rail (panel board / distribution board)
Method of connection	Not associated with mechanical mounting
Rated residual operating current (A).....	30 mA, 100 mA, 300 mA, 500 mA
Rated current (A)	16 A, 25 A, 32 A, 40 A, 63 A, 80 A
Rated voltage (V)	230 V / 240 V
Rated impulse withstand voltage (U_{imp})	4 kV
Nature of supply.....	a.c.
Rated frequency (Hz)	50/60 Hz

Rated making and breaking capacity (A)..... : 800 A	
Rated residual making and breaking capacity (A)..... : 800 A	
Rated conditional short-circuit current (A) : 10000 A	
Rated conditional residual short-circuit current (A) ... : 10000 A	
Type of terminal..... : Cage	
Possible test case verdicts:	
- test case does not apply to the test object..... : N/A	
- test object does meet the requirement..... : P (Pass)	
- test object does not meet the requirement..... : F (Fail)	
Testing	
Date of receipt of test item..... : 06/2018 – 07/2019, 06/2020	
Date (s) of performance of tests : 06/2018 – 07/2019, 06/2020 - 07/2020	
General remarks:	
<p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p> <p>RCCB's EFI-P2 type AC are the same as RCCB's EFI-P2 type A, only marking plate is different in symbol for type AC or A – test results of EFI-P2 type A also applies for EFI-P2 type AC.</p> <p>This TRF replaces TRF 2224145.50 issued on 2019-10-03. The EFI-P2R types with reset position have been added in this TRF.</p> <p>N.B.: Projects performed under the IECEE CB-Scheme CTF procedure, are fully in line with the procedures and requirements of the IECEE CB-Scheme, but do not fall under DEKRA Netherland's laboratory accreditation, according to ISO/IEC 17025, by the Dutch Accreditation Council.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IECEE 02:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided.....:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies)..... : ETI Elektroelement d.o.o. Obrezija 5 SI-1411 Izlake Slovenia	

General product information:

EFI-P2 reference list:

Rated current (A)	Rated $I_{\Delta n}$ (A)	ETI Code number	
		Type A	Type AC
16	0,03	002061110	002061210
25	0,03	002061111	002061211
40	0,03	002061112	002061212
63	0,03	002061113	002061213
80	0,03	002061114	002061214
16	0,1	002061120	002061220
25	0,1	002061121	002061221
40	0,1	002061122	002061222
63	0,1	002061123	002061223
80	0,1	002061124	002061224
16	0,3	002061130	002061230
25	0,3	002061131	002061231
40	0,3	002061132	002061232
63	0,3	002061133	002061233
80	0,3	002061134	002061234
16	0,5	002061140	002061240
25	0,5	002061141	002061241
40	0,5	002061142	002061242
63	0,5	002061143	002061243
80	0,5	002061144	002061244

EFI-P2R reference list:

Rated current (A)	Rated $I_{\Delta n}$ (A)	ETI Code number	
		Type A	
16	0,03	002061460	
25	0,03	002061461	
40	0,03	002061462	
63	0,03	002061463	
80	0,03	002061464	
16	0,1	002061470	
25	0,1	002061471	
40	0,1	002061472	
63	0,1	002061473	
80	0,1	002061474	
16	0,3	002061480	
25	0,3	002061481	
40	0,3	002061482	
63	0,3	002061483	
80	0,3	002061484	
16	0,5	002061490	
25	0,5	002061491	
40	0,5	002061492	
63	0,5	002061493	
80	0,5	002061494	

EFI-P2R has a handle with reset position. In all other aspects the products are identical to the EFI-P2.



OD ECS 040-1
January 2019

Responsible CB



TEST REPORT SUMMARY

Report Number.....	2247906.50
Date of issue.....	2020-07-09
Tested by (name, function, signature):	B. Pesan (R&D Laboratory Manager)
Witnessed by (name, function, signature):	R. Verhagen (Project Manager Industrial Safety)
Approved by (name, function, signature):	F.S. Strikwerda (Project Manager Industrial Safety)
Supervised by (name, function, signature):	-
Testing Laboratory.....	DEKRA Certification B.V.
Address	Meander 1051, 6825 MJ Arnhem, The Netherlands
Testing procedure.....	<input type="checkbox"/> ENEC <input checked="" type="checkbox"/> CCA NTR <input type="checkbox"/> ENEC based on IEC EE CBTC with number:
Customer Testing Procedure.....	<input type="checkbox"/> TMP/CTF Stage 1 <input checked="" type="checkbox"/> WMT/CTF Stage 2 <input type="checkbox"/> SMT/CTF Stage 3
Applicant.....	ETI Elektroelement d.o.o.
Address	Obrezija 5, SI-1411 Izlake, Slovenia
Manufacturer.....	ETI Elektroelement d.o.o.
Address	Obrezija 5, SI-1411 Izlake, Slovenia
Product.....	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)
Model/Type reference	EFI-P2, EFI-P2R
Trademark	ETI
Ratings	16 A, 25 A, 32 A, 40 A, 63 A, 80 A / 30 mA, 100 mA, 300 mA, 500 mA / Type A, AC / 230 V, 240 V / 2p (1p+N) / 50/60 Hz
Certification Scheme	<input type="checkbox"/> ENEC <input checked="" type="checkbox"/> CCA <input type="checkbox"/> Other:
Standard(s).....	EN 61008-1:2012+A1:2014+A2:2014 used in conjunction with EN 61008-2-1:1994 + A11:1998
<input type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC is equivalent with the corresponding IEC Publication.	
<input checked="" type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC with agreed common modifications and is <u>not</u> equivalent with the corresponding IEC Publication. An EU Deviation Addendum has to be issued.	
This EN test report consists of the following parts:	
<input checked="" type="checkbox"/> IEC Test Report Number.....	IEC61008_1H 2247906.50
<input checked="" type="checkbox"/> EU Deviation Addendum.....	EU_GD_IEC61008_1H 2247906.50
Copyright © 2019, ETICS Brussels, Belgium. All rights reserved.	
This ECS document together with the test report is only valid if signed by an approved ENEC or CCA Testing Laboratory and accompanied by the associated ENEC Licence or CCA Notification of Test Results, issued by a Certification Body member of ECS.	