



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **14262-044-01**

Valid from: 2020 10 08
until: 2022 10 08

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **ETI Elektroelement d.o.o.**
Obrezija 5
1411 Izlake
Slovenia

Product: **Low-voltage fuse links**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **SGP-05509/NH3C/500V/gG/OVE**

Österreichischer Verband für Elektrotechnik
Head of Testing and Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 09 02



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

ETI Elektroelement d.o.o.
Obrezija 5
1411 Izlake
Slovenia

Factory location(s):

ETI Elektroelement d.o.o.
Obrezija 5
1411 Izlake
Slovenia

ETI Polam Sp. z.o.o.
ul. Jana Pawla II 18
06-100 Pultusk
Poland

Tested and certified according to:

ÖVE/ÖNORM EN 60269-1:2015-06-01
ÖVE/ÖNORM E 8669-2:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

Product: Low-voltage fuse links

Type designation:

Rating:

Trademark:

NH 3C / NV 3C
Rated voltage: AC 500 V
Rated current: 80 A
120 kA
gG

ETI

NH 3C / NV 3C
Rated voltage: AC 500 V
Rated current: 100 A
120 kA
gG

ETI

NH 3C / NV 3C
Rated voltage: AC 500 V
Rated current: 125 A
120 kA
gG

ETI

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 160 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 200 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 224 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 250 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 280 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 300 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 315 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 355 A
120 kA
gG

ETI

NH 3C / NV 3C

Rated voltage: AC 500 V
Rated current: 400 A
120 kA
gG

ETI

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.