OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

OVE Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 14262-054-01 Valid from: 2021 06 03

until: 2023 06 03

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

ETI Elektroelement d.o.o. Company:

> Obrezija 5 1411 Izlake Slovenia

Product: Low-voltage fuse links

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: SGP-10364/NH2I/400V/gG/OVE

Österreichischer Verband für Elektrotechnik

Head of OVE Certification


Digitally signed by T. Neumayer

Dipl.-Ing. T. Neumayer



Wien, 2021 05 20

OVE Certification







Certificate No.: 14262-054-01

Date: 2021 05 20 Page 2 of 3

Manufacturer:

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

Factory location(s):

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

Tested and certified according to:

ÖVE/ÖNORM EN 60269-1:2015-06-01 ÖVE/ÖNORM E 8669-2:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Trademark:

Product: Low-voltage fuse links

Type designation:

Rating:		
NH2I / NV2I Rated voltage: AC 400 V Rated current: 280 A 120 kA gG	ETI	
NH2I / NV2I Rated voltage: AC 400 V Rated current: 300 A 120 kA gG	ETI	
NH2I / NV2I Rated voltage: AC 400 V Rated current: 315 A 120 kA gG	ETI	







Certificate No.: 14262-054-01

Date: 2021 05 20

Page 3 of 3

NH2I / NV2I ETI

Rated voltage: AC 400 V Rated current: 355 A

120 kA gG

NH2I / NV2I ETI

Rated voltage: AC 400 V Rated current: 400 A

120 kA gG

