

## **EU - Declaration of conformity**

Manufacturer: ETI Elektroelement d.o.o.

Address: Obrezija 5, 1411 Izlake, SLOVENIA

<u>Products:</u> NV (NH) gG Low-voltage Fuse Links, KOMBI Type

(with combined indicating devices, insulated and non-insulated gripping-lugs)

Size NV 3 / NH 3

425A - 630A / 400V a.c. NV/NH3 and 200A - 630A / 400V a.c. NV/NH3I 425A - 630A / 500V a.c. NV/NH3 and 200A - 630A / 500V a.c. NV/NH3I 355A - 500A / 690V a.c. NV/NH3 and 200A - 500A / 690V a.c. NV/NH3I

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The object(s) of the declaration described above is (are) in conformity with the relevant Union harmonisation legislations:

## 2014/35/EU

Directive of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits; Official Journal of the EU L96, 29/03/2014, p. 357-374 (from 20.04.2016).

## 2011/65/EU

Directive of the European Parliament and of the Council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (recast).

## 2015/863/EU

Directive of the European Parliament and of the Council of 31 March 2015 on the restriction of the use of certain hazardous substances in electrical and electronic equipment, amending Annex II of Directive EU 2011/65/EU - RoHS3, (from 22.07.2019)

Our products are constructed and manufactured based on our Quality Management System (according to DIN EN ISO 9001) in correspondence to the following standards:

Harmonized European

<u>standards:</u> DIN EN 60269-1:2015-05, EN 60269-1:2007 + A1:2009 + A2:2014

DIN VDE 0636-2:2014-09, HD 20269-2:2013

*IEC standards:* **IEC 60269-1 Ed.4.2:2014-06,** 

IEC 60269-1:2006 + AMD1:2009 + AMD2:2014,

IEC 60269-2 Ed.5.1:2016-08, IEC 60269-2:2013 + AMD1:2016

7

**National standards: VDE 0636-1:2015-05, VDE 0636-2:2014-09,** 

Type test reports: CB - Test Report SGP-05509/NH3/500V/gG/CB/1,

CB - Test Report SGP-05509/NH3I/500V/gG/CB/1

*Marking with CE:* On the product / On the packaging

Affixing of the CE-marking: 2001

Place and date: Izlake, 29.02.2024

Manufacturer representative

signature and stamp: Viktor Martinčič, univ.dipl.ing.